



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFOSRT/2022/00022631

Date: 12/06/2024

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFOSRT/2022/00022631/R1

Building Occupancy/Category: Educational (non-residential)

To,

RELIABLE EDUCATIONAL TRUST

Plot No.12 Gunjan Area Nr.Upasana School GIDC Vapi VAPI Valsad 396195

Fire Region: Surat RFO

Mobile No: 9825800898 Email ID: shreekrishna.school2010@gmail.com

This has reference to your Application No. 2024/00064633 dated 08/06/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise Shree Krishna International School (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: GIDC Vapi
5. Name of Block(s): Shree Krishna International School

The building/premise was inspected on 12/06/2024 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 12/06/2024
2. Six monthly inspection was done on 12/06/2024

The Fire Safety Certificate is renewed for a period of two (2) years upto 12/06/2026 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Hirang Shirishbhai Patel
Fire Safety Officer - General (FSO-G)
2021/001285

Date: 12/06/2024
Time: 04:52 PM



FSCA/O/RFOSRT/2022/00022631/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.

